

THIS DETAIL IS FOR AREAS OF
LOW WAVE ENERGY AND
STREAM VELOCITY

INSTALL WALL TOE BAG STABILIZER AT
FIRST COURSE ABOVE LEVELING PAD PER
ENGINEERING REQUIREMENTS AND
INSTALLATION GUIDE**

SETBACK MAY VARY
(2" THROUGH 6"
PER COURSE)

2 ENVIROLOK SPIKES
PER BAG

VEGETATE WALL FACE
PER INSTALLATION GUIDE
AND SPECIFICATIONS**



PLACE 2"-MINUS FILLED BASE BAGS
PERPENDICULAR TO
WALL FACE OR DOUBLE-
WIDE PER INSTALLATION GUIDE**

SCALE: NONE

* MINIMUM 12" EMBEDMENT. EMBEDMENT
INCREASES WITH INCREASED WALL HEIGHTS,
SLOPING FILLS IN FRONT AND BEHIND WALL
OR POOR FOUNDATION SOILS. CONTACT
ENGINEER FOR REQUIREMENTS.

NOT FOR CONSTRUCTION

**NOTE: SEE INSTALLATION GUIDE FOR
VEGETATION OPTIONS AND INSTALLATION
GUIDE FOR DETAILS AND OPTIONS.

THESE DETAILS ARE INTENDED FOR PRELIMINARY DESIGN PURPOSES
ONLY. FINAL DETERMINATION OF THE SUITABILITY OF ANY
INFORMATION OR MATERIAL IS THE SOLE RESPONSIBILITY OF THE USER.
A FINAL PROJECT SPECIFIC DESIGN SHOULD BE PREPARED BY A
QUALIFIED, LICENSED, PROFESSIONAL ENGINEER.



2918 AGRICULTURE DRIVE
MADISON, WI 53718
PHONE: 608-226-2544

ENVIROLOK

UNREINFORCED SHORELINE WALL

SCALE	AS NOTED
DRAWN BY	PDS
CHECKED BY	PDS
DATE	DECEMBER, 2006
DWG. NO.	UNREINFORCED SHORELINE